Scott. II-27--40,000--'6--

Public Works Factories

P.W.

(193 /) Departmental

SERIES.

G.O. No.	14 6.3
DATED	21.1.37

[Despatch Abstract.]

ELECTRICITY - Collegial Electric Licence - Earthed neutral [illegible] -

Relaxation of rule 9 (a) - Permitted subject to conditions.

Local Fund **DEPARTMENT.**

Received ..... 19 *Registered* ...

Subject.

Electrification Scheme — Kollegal Panchayat Board Coimbatore District — Earthed Neutral System — Sanction requested

ENCLOSURES.
No.
Spare copies.....

Roc. No. 488/K.P.B of 32

Station Kollegal, Dated the 2.8.37 June 1937

From (Name) M. P. Ry. C. K. Nagiah, avl
(Designation) President Panchayat Board Kollegal

To The Secretary to the Government of Madras,

Through, The Electrical Inspector Madras (Power works) Department.
Through The President District Board Erode.

Sir,

I have the honour to state that it is proposed to use an earthed neutral system for the Kollegal electrification scheme for which sanction of Government is requested

It is understood that this system is fairly common and up to date

I therefore request that the Government would be pleased to accord sanction for the same.

I have the honour to be
Sir
Your most obedient servant

28/8

President Panchayat Board

Copy to the President District Board Coimbatore
Copy to the Electrical Inspector Madras.

SECRETARY TO GOVT.
12 JUL 1937
PUBLIC WORKS DEPT.

Office of the Chief Engineer
for Electricity,
Chepauk, Madras.

Sub:- Electrification Scheme - Kollegal Panchayat Board - Coimbatore District - Earthed neutral system.

Ref:- Letter No.Roc.488/K.P.B.of 32 dated 28.6.1937.

Endorsement No.8575/37-G-1 dated 8th July 1937.

Forwarded to the Secretary to Government, Public Works Department.

2. I recommend that rule 58(a) of the Indian Electricity Rules 1937 be relaxed subject to the following conditions:-

I. The neutral be insulated in accordance with Rule 58(a) within six months of advice being given by the Electrical Inspector.

II. The particular areas in which such earthed neutrals be used shall be specified by the Electrical Inspector, and

III. The use of such neutrals shall in no way prejudice any underground structures, the local telephone or telegraph communications, nor the utility of any system of protection installed.

10.7.37
for Chief Engineer (Electricity).

To The Secretary to Government,
Public Works Department(with letter in original).

MRS:N.